

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR FILTER

SITE AND BLDG #: VA049-01

LOCATION/RM #: ceiling filters

MECHANIC
SIGNATURE: *Tm L*

DATE: 2/12/19

START TIME: 900AM

FINISH TIME: 100PM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA049-01	7254	2323					J-1502000-11 16-pc Air Filter, Ceiling	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			
2	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Disconnect the power to the unit.			
2	Remove the intake grille by removing all screws around the edges.			
3	Vacuum and wash (if necessary) to remove the buildup of dirt and debris.			
4	If necessary, lubricate the motors.			
5	Reinstall the cover and intake grille.			
6	Verify proper operation of unit. Make and/or recommend any needed repairs.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

