

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**FAN COIL UNIT**

SITE AND BLDG #: VA049-01 (PM), PM filters  
 LOCATION/RM #: Hallway, offices WO# XXXX 13196 ASSET # 2317, 34127  
 Corridors 13202, 13257 34129, 34129  
 34130, 34131

MECHANIC SIGNATURE: Richard Walker DATE: 18 2021  
 START TIME: 9am FINISH TIME: 5PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check fan blades for dust buildup and clean if necessary.	✓		
2	Check fan blades and moving parts for cracks and excessive wear.	✓		
3	Tighten all electrical connectors to proper torque as needed.	✓		
4	Check that the fan runs properly in all speeds as applicable.	✓		
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	✓		
7	Lubricate mechanical connections of dampers sparingly as applicable.	✓		
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a CM.	✓		
9	Clean coils by brushing, blowing, vacuuming	✓		
10	Check coils for leaking, tightness of fittings.	✓		
11	Use fin comb to straighten coil fins as needed.	✓		
12	Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.	✓		No Belts
13	Check rigid couplings for alignment on direct drives, and for tightness of assembly	✓		
14	Vacuum interior of unit.	✓		
15	Check filter door for proper gasketing and air leaks. Correct as needed.	✓		
16	Change the filter as needed with the correct size and type filter.	✓		Filter gets checked Quarterly <u>Washable</u>
17	Insure that drain(s) are clear and running. - Install condensate tablet	✓		
18	Clean up work area. - Record Humidity level in area	✓		Humidity <u>18, 22, 23, 24</u> %

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**