

Tidewater, INC
 VA-049
 6700 Strathmore Rd.
 North Chesterfield VA 23237
 (410) 540-8700

Recorded By: Jon Miller
 (301) 580-9820
 jmiller@bondwater.com

Boiler Room - HVAC Equipment

Test	Hot Loop	Chill Loop		
Conductivity (as mmhos)	960 4000 max	610 4000 max		
pH	9.3 8 - 10.5	9.6 8 - 10.5		
Molybdate (ppm as Mo)	190 50 min	140 50 min		

Opening Comment

Performed scheduled service visit.

Hot Water Loop

Online 

All readings indicate good levels of protection for closed system. Corrosion inhibitor residual is excellent at this time. Replaced filter in filter housing.

Chill Water Loop

Offline 

All readings indicate good levels of protection for closed system. Corrosion inhibitor residual is excellent at this time. Chill Loop is Offline

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its insurers are not liable for losses caused by the Customer's wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.