

Tidewater, INC
VA-049
6700 Strathmore Rd.
North Chesterfield VA 23237
(410) 540-8700

Recorded By: Jon Miller
(301) 580-9820
jmillier@bondwater.com

Boiler Room - HVAC Equipment

Test	Hot Loop	Chill Loop		
Conductivity (as mmhos)	1509 4000 max	1010 4000 max		
pH	10.2 8 - 10.5	10.5 8 - 10.5		
Molybdate (ppm as Mo)	200 50 min	200 50 min		

Opening Comment

Performed scheduled service visit.

Filtration housings have recently been installed, will change chill water filter on August visit.

Hot Water LoopOnline 

All readings indicate good levels of protection for closed system. Corrosion inhibitor residual is excellent at this time.

Chill Water LoopOnline 

All readings indicate good levels of protection for closed system. Corrosion inhibitor residual is excellent at this time.