

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST WATER PUMP

SITE AND BLDG #: VA050-01

MECHANIC
SIGNATURE: Tin A

DATE:

LOCATION/RM #: MECH RoomSTART TIME: 9 AMFINISH TIME: 12 PM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA050-01	7639	1669		B B G	1531	187001	J-1502000-12 2-pc Hot Water Pump 47GPM, 40ft	mech room
VA050-01	7639	1670		B B G	1531	187006	J-1502000-12 2-pc Chill Water Pump 128GPM, 46ft	..
VA050-01	7639	1671		B B G	1531	187001	J-1502000-12 2-pc Hot Water Pump 47GPM, 40ft	..

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			
2	Schedule shutdown with operating personnel.			
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check valve for full stroke operation in both directions, if applicable.			
2	Check valve for signs of abnormal wear and leaks. Replace packing if needed.			checked for leaks
3	Clean the coil with vacuum cleaner.			
4	Comb the fins as needed.			
5	Clean all fans and motors.			

6	Check operation of controls and safeties.			
7	Lubricate as required.			
8	Check all motors, belts, pulleys, shafts, etc. for alignment.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

2.33 amps on Running Pumps

