

Tidewater, INC
VA-050
6002 Strathmore Rd.
North Chesterfield VA 23232
(410) 540-8700

Recorded By: Jon Miller
(301) 580-9820
jmillier@bondwater.com

Rear Mechanical Room - HVAC Equipment

Test	Hot Loop	Chill Loop		
Conductivity (as mmhos)	351 4000 max	3885 4000 max		
pH	9.4 8 - 10.5	9.6 8 - 10.5		
Molybdate (ppm as Mo)	40 40 min	200 40 min		

Opening Comment

Performed quarterly scheduled service visit.

Hot Water LoopOnline 

Corrosion inhibitor residual is excellent at this time. All readings indicate good levels of protection for closed system.

Chill Water LoopOnline 

Corrosion inhibitor residual is excellent at this time. All readings indicate good levels of protection for closed system.