

## Tina Lee

---

**From:** Richard Hicks  
**Sent:** Wednesday, May 11, 2022 4:52 PM  
**To:** tmoronez5@gmail.com; Angela.W.Williams-Taylor.ctr@army.mil; Augustin, Kenneth P CIV USARMY 99 RD (USA); Mary Lowery; Karlee Demain; Ryan Willis; Adam Colopy; Tina Lee; William Schultz  
**Cc:** Devlin, Thomas J CIV USARMY CENAP (US)  
**Subject:** VA050 Chiller UPDATE - CSS Tickets needed please

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

Tony , Angela , Team ,  
Tony - VA050 Chillers are Online – Please provide a CSS Ticket for needed trouble shooting and repairs .

**Chiller #1 -CSS#** [REDACTED] - Chiller #1 has to contactors that need to be replaced. Also found fuse blown due to a condenser fan motor bad and single phasing the fuse. Earl from Moores will swing by Friday and replace fuse so he can determine which fan motor is bad

**Chiller #2 -CSS#** [REDACTED] -- Chiller #2 has 2 bad contactors as well as supply and return chilled water sensors that are bad.

Note : Earl from Moores will work up a quote to repair all the deficiencies.

Both Chillers are working right now but repairs will need to be addressed before the hot days of summer arrive.

Thanks,  
Rick

Rick Hicks  
Project Manager Region 5  
CMI Management Inc.  
5285 Shawnee Road Suite #510  
Alexandria,VA 22312  
703-738-5301  
Richard.Hicks@cmimgmt.com