

Tidewater, INC
 VA-050
 6002 Strathmore Rd.
 North Chesterfield VA 23232
 (410) 540-8700

Recorded By: Jon Miller
 (301) 580-9820
 jmiller@bondwater.com

Rear Mechanical Room - HVAC Equipment

| Test | Hot Loop | Chill Loop | | |
|-------------------------|-----------------|------------------|--|--|
| Conductivity (as mmhos) | 225 4000 max | 3770 4000 max | | |
| pH | 9.5 8 - 10.5 | 9.9 8 - 10.5 | | |
| Molybdate (ppm as Mo) | 20 40 min | 200 40 min | | |

Opening Comment

Performed quarterly scheduled service visit.

Hot Water Loop

Offline 

Corrosion inhibitor residual is slightly low at this time, will pump in more BOND 5011 treatment on next visit when system is in circulation. Hot Loop is Offline

Chill Water Loop

Online 

Corrosion inhibitor residual is excellent at this time. All readings indicate good levels of protection for closed system.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its insurers are not liable for losses caused by the Customers wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.