

Tina Lee

From: Richard Hicks
Sent: Thursday, July 14, 2022 3:51 PM
To: Tina Lee
Subject: FW: VA050 Chiller update

Importance: High

From: Richard Hicks
Sent: Thursday, July 14, 2022 1:47 PM
To: Moronez, Antonio G CIV USARMY 99 RD (USA) <antonio.g.moronez.civ@army.mil>; Angela.W.Williams-Taylor.ctr@army.mil
Cc: Shara Fortier <Shara.Fortier@tideh2o.net>; Mary Lowery <Mary.Lowery@tideh2o.net>; Adam Colopy <adam.colopy@tideh2o.net>
Subject: VA050 Chiller update
Importance: High

Tony , Angelia ,
The chillers are back online at VA050 . The site power loss was the cause .

Work Order	Description	Site	Location / Fac. ID
18473	Air condition is not cooling as it should, building getting hot at 10 am this morning.	99REG5	VA050-01

Thanks,
Rick

Rick Hicks
Project Manager Region 5
CMI Management Inc.
5285 Shawnee Road Suite #510
Alexandria,VA 22312
703-738-5301
Richard.Hicks@cmimgmt.com