



Proudly serving the entire states of Virginia & North Carolina.

Altavista, VA • Charlottesville, VA • Chesapeake, VA • Manassas, VA
Lynchburg, VA • Richmond, VA • Raleigh, NC • Charlotte, NC

P.O. Box 119 • Altavista, VA • 800.789.7199 • service@mooreselectric.com

Billing Address		Site Address
Customer:	TIDEWATER, INC	Customer: USARC VA050 N CHESTERFIELD
Address:	6625 SELNICK DRIVE ELKRIDGE MD 21075	Address: 6002 STRATHMORE ROAD NORTH CHESTERFIELD VA 23232
Phone:	614-623-9569	Phone: 410-688-0142
Service Call #: COM0177664		Call Type: COM-PM

Service Requested

VA050-01 XXXX 2346 PM-SA-2343 J-1502000-04 1-pc Chiller, Air Cooled Trane Moores Mechanical schedule 5/11

Problems

Description	Tech	Equip. Desc and Model	Manufacturer	Equip. Serial	Asset ID
Commercial Planned Maintenance	PETELANGST				
Commercial Planned Maintenance	EARLWARE	Chiller 2 M# CGAFC604ARA1000DE	Trane	C09E14916	

Tech Notes

Site Start - 5/11/2022 3:30 PM
Site Stop - 5/11/2022 5:00 PM

Performed pm on chiller per pm scope. During pm, found that a condenser fan motor fuse was blown and circuit 1 off by hp lockout. Checked the fans and found one fan motor that has shorted windings causing the fuse to blow. Isolated fan from circuit. Also found two compressor contractors that are worn and need to be replaced. Restored operations to the chiller, chiller is operational at this time. A quote for repairs will be made.
This work order is complete.

Labor

Date	Technician	Description	Hours
5/12/2022	EARL WARE	REGULAR HEAVY COMMERCIAL LABOR	1.50

Materials

Date	Part Number	Description	Quantity
No records found			

Signed By	Dabney	Signature	Date	5/12/2022
				