



Proudly serving the entire states of Virginia & North Carolina.

Altavista, VA • Charlottesville, VA • Chesapeake, VA • Manassas, VA
Lynchburg, VA • Richmond, VA • Raleigh, NC • Charlotte, NC

P.O. Box 119 • Altavista, VA • 800.789.7199 • service@mooreselectric.com

Billing Address		Site Address	
Customer:	TIDEWATER, INC	Customer:	USARC VA050 N CHESTERFIELD
Address:	6625 SELNICK DRIVE ELKRIDGE MD 21075	Address:	6002 STRATHMORE ROAD NORTH CHESTERFIELD VA 23232
Phone:	614-623-9569	Phone:	410-688-0142
Service Call #: COM0177665		Call Type: COM-PM	

Service Requested

VA050-01 XXXX 2347 PM-SA-2343 J-1502000-04 1-pc Chiller, Air Cooled Trane Moores Mechanical scheduled 5/11

Problems

Description	Tech	Equip. Desc and Model	Manufacturer	Equip. Serial	Asset ID
Commercial Planned Maintenance	PETELANGST				
Commercial Planned Maintenance	EARLWARE	20 ton chiller M#CGAFC204ARA1000DE	Trane	C09E14915	

Tech Notes

Site Start - 5/11/2022 1:00 PM
Site Stop - 5/11/2022 3:30 PM

Arrived on site, checked in with site technician. Proceeded to perform chiller p.m. as outlined in scope of work. During p.m., found that the machine will need 2 compressor contractors and will need new water temp sensors as they are reading out of range. These repairs will be quoted, chiller is operational at this time. This work order is complete.

Labor

Date	Technician	Description	Hours
5/12/2022	EARL WARE	REGULAR HEAVY COMMERCIAL LABOR	2.50

Materials

Date	Part Number	Description	Quantity
No records found			

Signed By	Dabney	Signature	Planned Dabney	Date	5/12/2022