

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**FENCES**

**SITE AND BLDG #:** VA099-01 **1434**

**MECHANIC  
SIGNATURE:** 

**DATE:** 07-28-22

**LOCATION/RM #:** WO#18228 **ASSET #**

**START TIME:** 0900

**FINISH TIME:** 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check posts and corner posts, support guys, and horizontal bars between each support post.	/		
2	Check wire and anchor point; re-stretch and re-anchor if necessary.	/		
3	Inspect fence anchors along the bottom of the fence and at the point where the fence is connected to the post.	/		
4	Report any damage to fence that would cause a security concern	/		
5	Inspect the bottom of the fence to ensure that there is not a gap larger than 2 inches under the fence.	/		
6	Check the top guard and ensure that it is properly fastened (angled out) and the wires are tight.	/		
7	Inspect all wire ties. Note any deficiencies	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**