

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
PHOTOCELL

SITE AND BLDG #: VA099-01

MECHANIC
SIGNATURE: *Tu L*DATE: *5/28/19*LOCATION/RM #: *POV*START TIME: *10 AM*FINISH TIME: *11 AM*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA099-01	8503	1613	PM-QT-1613				J-1502000-43 14-pc PhotocellPOV Lights	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			
2	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean timeclock using a soft lint-free cloth and spray bottle of glass cleaner. Remove any dirt or grease build up.			
2	Check physical connections.			
3	Verify the timeclock configuration, ensure proper operation.			
4	If applicable, check battery and replace as needed.			

Note: The technician shall perform any repairs identified during PM found exceeding \$250 open a corrective maintenance (CM) ticket and performed by: General Maintenance Worker **Additional Notes:**

direct material cost) per PM occurrence. For any deficiencies, photos, and a detailed description of the deficiency. To be

