

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

THERMOSTATS

MECHANIC
SIGNATURE: *Tn L*

DATE:

4/23/19

SITE AND BLDG #: VA099-01

START TIME: 10 AM

FINISH TIME: 1130 AM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA099-01	8229	1427		<i>Trane</i>			J-1502000-17 25-pc Thermostat, DigitalThroughout	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			
2	Always follow lock out/tag out procedures. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If EMS (Energy Management System) If it is EMS controlled 1- We log into computer with user name and password for EMS or DDC obtained from site personnel. 2- Validate set point and actual temp at computer			
2	Review all zone set points at the server IF Applicable			
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.			
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low-pressure air.			
5	If applicable, replace battery as needed.			
6	Use our own Temperature meter to validate the computer is correct. If it is not EMS or DDC controlled take our temperature meter and check against actual thermostat and record temperature			

Note: The technician shall perform any repairs identified during PM up to \$250 (does not exceed \$250 open a corrective maintenance (CM) ticket and include the Asset #)

To be performed by: HVAC Technician

Additional Notes:



PM occurrence. For any deficiencies found, record the description of the deficiency.