

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

WATER HEATER

SITE AND BLDG #: VA099-01

**MECHANIC
SIGNATURE:** *Tm L*

DATE: 2/27/19

LOCATION/RM #:

START TIME: 1100PM

FINISH TIME: 400PM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA099-01	7250	1610		<i>Lochinvar</i>			J-1502000-27 1-pc Water Heater	110
VA099-01	7250	1611		<i>Lochinvar</i>	BVU 200		J-1502000-27 1-pc Water Heater	110
VA099-01	7250	1612			RGA0432		J-1502000-27 1-pc Water Heater	110
VA099-02	7251	1614		<i>Eemax</i>	EJJ020FS 102		J-1502000-27 1-pc Water HeaterElectric	117
VA099-02	7251	1615		<i>Lochinvar</i>		1244J007971	J-1502000-27 1-pc Water Heater 19 GAL Electric	107

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			
2	Schedule shutdown with operating personnel.			
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check valve for full stroke operation in both directions, if applicable.			
2	Check valve for signs of abnormal wear and leaks. Replace packing if needed.			
3	Clean the coil with vacuum cleaner.			

4	Comb the fins as needed.			
5	Clean all fans and motors.			
6	Check operation of controls and safeties.			
7	Lubricate as required.			
8	Check all motors, belts, pulleys, shafts, etc. for alignment.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

water heater does not have relief valve It is located on the storage tank.

