

## PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

### MANUAL/AUTOMATIC OVERHEAD DOORS

SITE AND BLDG #: VA099-03 2393

LOCATION/RM #:                      WO# 18270 ASSET #                     

MECHANIC SIGNATURE:  DATE: 07-28-22

START TIME: 0900 FINISH TIME: 1630

| CHECK POINT                                | CHECKPOINT DESCRIPTION                                                                                                                                                                                                                | TASK COMPLETE                                                                        |    | NOTES/ ACTIONS<br>(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION) |
|--------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------|----|-------------------------------------------------------------------------|
|                                            |                                                                                                                                                                                                                                       | YES                                                                                  | NO |                                                                         |
| SPECIAL INSTRUCTIONS                       |                                                                                                                                                                                                                                       |                                                                                      |    |                                                                         |
| 1                                          | Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.                                                                           |    |    |                                                                         |
| TO BE PERFORMED AT EACH INSPECTION SERVICE |                                                                                                                                                                                                                                       |                                                                                      |    |                                                                         |
| 1                                          | Check with door operating personnel for any known deficiencies.                                                                                                                                                                       |    |    |                                                                         |
| 2                                          | Inspect general arrangement of door and mechanism, mountings, standards, wind locks, anchor bolts, counterbalances, weather stripping, door sweeps etc. Clean, tighten, and adjust repair as required.                                |    |    |                                                                         |
| 3                                          | If applicable, operate with power from start to stop and at intermediate positions. Observe performance of various components, such as brake, limit switches, door operating speed, motor, gear box, etc. Clean and adjust as needed. |    |    |                                                                         |
| 4                                          | Check operation of safety edges, stops, electric eye, treadle, or other operating devices. Clean and make required adjustments or repairs.                                                                                            |    |    |                                                                         |
| 5                                          | Check manual operation. Note brake release, motor disengagement, functioning or hand pulls, chains sprockets, clutch, etc.                                                                                                            |   |    |                                                                         |
| 6                                          | If applicable, examine all wiring, motor, starter, push button, etc., blow out or vacuum if needed.                                                                                                                                   |  |    |                                                                         |
| 7                                          | If applicable, inspect gear box, change or add oil as required.                                                                                                                                                                       |  |    |                                                                         |
| 8                                          | Perform required lubrication. Remove old or excess lubricant.                                                                                                                                                                         |  |    |                                                                         |
| 9                                          | Clean unit and mechanism thoroughly.                                                                                                                                                                                                  |  |    |                                                                         |
| 10                                         | Clean up and remove all debris.                                                                                                                                                                                                       |  |    |                                                                         |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**