

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA099 Date of Visit: 11.12.2020

Contractor Personnel on Site:

1. _____	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 25526 WO# 12446

Description of Repairs

removed old usarc led sign, and installed new weatherproof led spotlight, adjusted light to illuminate entire sign.

drilled hole in electrical box, due to being full of water on a 240v line. to drain water from live electricity.

once water was safely evacuated, I switched out light.

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Richard Walker Date: 11.12.2020

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Don Huson Date: 11.12.2020

Signed: 

E-Mail: _____

