

CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA099 Date of Visit: 9.10.2020

Contractor Personnel on Site:

1. <u>Richard Walker</u>	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO'S 11832-AN, 11833-AN, 11834-AN
2. Above Ground Propane Tanks, Grounding Rod, Lightning Rod
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard Walker Date: 9.10.2020

Signed: Richard Walker

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Don Huson Date: 9.10.2020

Signed: Don Huson

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTNING PROTECTION

SITE AND BLDG #: VA099-03

LOCATION/RM #: *Storage*
WO# 11834 ASSET # 1447,1448MECHANIC
SIGNATURE:*Richard Walker* DATE: 9/10/2020

START TIME:

9 am

FINISH TIME:

5PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	During the first inspection, check that: a) All air terminals (lightning rods) are interconnected. b) At least two down conductors are installed with their own ground connection.	<input checked="" type="checkbox"/>		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect air terminals for corrosion and rigid attachment to structure.	<input checked="" type="checkbox"/>		
2	Examine conductors and all connections for corrosion, strong mechanical joints which provide good electrical conductivity, and loose or broken fasteners.	<input checked="" type="checkbox"/>		
3	Check for loops, sharp bends (less than 8" radius) and frayed horizontal and vertical conductors.	<input checked="" type="checkbox"/>		
4	Check for damaged guards and down conductors.	<input checked="" type="checkbox"/>		
5	Inspect grounding attachment for permanency and corrosion (if practical).	<input checked="" type="checkbox"/>		
6	Clean up work area and remove debris.	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: