

Tidewater, INC  
 VA-099  
 1117 Harmony Dr.  
 Bedford VA 24523  
 (410) 540-8700

Recorded By: Jon Miller  
 (301) 580-9820  
 jmiller@bondwater.com

### Mechanical Room - HVAC Equipment

Test	Hot Loop	Chill Loop		
Conductivity (as mmhos)	3302 4000 max	3405 4000 max		
pH	8.0 8 - 10.5	9.7 8 - 10.5		
Molybdate (ppm as Mo)	75 50 min	55 50 min		

#### Opening Comment

Performed monthly scheduled service visit.

Took samples of chill water loop glycol and hot water loop glycol to verify glycol condition of both loops

#### Hot Water Loop

Offline 

All readings indicate good levels of protection for closed system. Corrosion inhibitor residual is excellent at this time. Hot Loop is Offline

#### Chill Water Loop

Online 

All readings indicate good levels of protection for closed system. Corrosion inhibitor residual is excellent at this time.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its insurers are not liable for losses caused by the Customer's wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.