

Tidewater, INC  
 VA-701  
 886 Carolina Road  
 Suffolk Virginia 23434-6040  
 (410) 540-8700

Recorded By: Jon Miller  
 (301) 580-9820  
 jmiller@bondwater.com

### Mechanical Room - HVAC Equipment

Test	Hot Loop	Chill Loop		
Conductivity (as mmhos)	3415 4000 max	2943 4000 max		
pH	10.3 8 - 10.5	10.0 8 - 10.5		
Sodium Nitrite (ppm as NaNO <sub>3</sub> )	1160 600 - 2000	1600 400 - 2000		

#### Opening Comment

Performed scheduled service visit.

#### Hot Water Loop

Online 

Corrosion inhibitor residual is excellent at this time providing excellent corrosion protection.

#### Chill Water Loop

Online 

Corrosion inhibitor residual is excellent at this time providing excellent corrosion protection.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its insurers are not liable for losses caused by the Customer's wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.