

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 10/5/20

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	3. _____
2. _____	4. _____

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO'S 9780AN, 9834-9837CAN,9909-9910FQT, 9988-9989MO, 10047-10049SA
2. 10192PMA,10201PMM,1220PMS, 9911-9912FQT, 1006QT, 10050-10051SA
3. 10016QT, 10050-10051SA
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 10/5/20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC PATRIC HANLON Date: 10/5/20

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
VEHICLE EXHAUST REMOVAL

SITE AND BLDG #: **NY051-02**MECHANIC
SIGNATURE: DATE: **10/5/20**LOCATION/RM #: **WO# 10016** ASSET # **10080**START TIME: **12:30pm**FINISH TIME: **1:30pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Start and stop fan with local switch	✓		switch functions properly
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.-Inspect hoses -report issues -open CM ticket	✓		used Lucas heavy duty Grease
3	Inspect, adjust belts and pulleys. Replace belt as needed.	✓		adjusted belt tension
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.	✓		all are tight
5	Inspect fan for bent blades, unbalance, excessive noise and vibration.	✓		no excessive noise
6	Clean fan as needed.	✓		fan is clean
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.	✓		no damage or leaks
8	Repair as needed	✓		no repairs needed

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: