

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 12/9/20

Contractor Personnel on Site:

- | | |
|-------------------------|------------|
| 1. <u>Patrick Brown</u> | 3. <u></u> |
| 2. <u></u> | 4. <u></u> |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO's 10729-10730PMFQT, 10808-10809PMMO, 10874-10875PMSA
2. 11043PMM, 11066PMS, 10731FQT, 10732FQT, 10836PMQT
3. 10876-10877PMSA, 11067PMS
4. FILTERS, GATES, HEATERS, WALL PACKS, FENCE, PTAC, EXHAUST
5.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 12/9/20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC PATRIC HANLON Date: 12/9/20

Signed: 

E-Mail:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

FILTER REPLACEMENT

SITE AND BLDG #: NY051-01

MECHANIC
SIGNATURE: 

DATE: 12/9/20

LOCATION/RM #:

WO# 10729

START TIME:

7am

FINISH TIME: 8am

10730

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Initial and Date Filter (if disposable)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Initial and Date Yellow Maintenance Tag (if applicable)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
ASSET #	SIZE	QTY		NOTES/ ACTIONS
	Record Size :			
10035	24x24x2/20x24x2	4/12		
10036	20x12x2	2		
	24x12x2	1		
	20x20x2	2		
	24x20x2	1		
	16x20x2	4		
	16x25x2	2		
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly			
	All other filters get replaced annually But inspected Quarterly			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: