

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY067 Date of Visit: 12/14/20

Contractor Personnel on Site:

- | | |
|-------------------------|------------|
| 1. <u>PATRICK BROWN</u> | 3. <u></u> |
| 2. <u></u> | 4. <u></u> |

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO's 10723PFQ,10746-10750PMFQT,10814MO, 10843-10843QT,
2. 10918-10923SA, 11044PMM,11075PMS,10845QT, 10924-10926SA,11076PMS
3. 10927SA,11077PMS
4. FILTERS, LIGHTING,SUMP PUMP, GREASE TRAP,HEATERS,GATES
5. WALL PACKS, EXHAUST SYSTEM

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Patrick Brown Date: 12/14/20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC WILLIAM MONTES Date: 12/14/20

Signed: 

E-Mail:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

FILTER REPLACEMENT

SITE AND BLDG #: NY067-01

MECHANIC
SIGNATURE

DATE: 12/14/20

LOCATION/RM #: WO# 10723
10746 - 10750

START TIME: 8am

FINISH TIME: 9am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	☒	☒	
2	Initial and Date Filter (if disposable)	☒	☒	
3	Initial and Date Yellow Maintenance Tag (if applicable)	☒	☒	
ASSET #	SIZE	QTY		NOTES/ ACTIONS
	Record Size :			
190917-423	8x27x1	2		
190917-424	"	2		
190917-427	"	2		
190917-428	"	2		
10547	20x20x2/20x24x2	6/9		
10548				
10549	12x24x2/24x24x2	3/3		
10550	20x20x2/24x20x2/13x24x2	6/2/3		
10558	20x20x2	6		
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly			
	All other filters get replaced annually But inspected Quarterly			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: