

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY039 Date of Visit: 12/8/20

Contractor Personnel on Site:

- | | |
|-------------------------|------------|
| 1. <u>Patrick Brown</u> | 3. <u></u> |
| 2. <u></u> | 4. <u></u> |

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO's 10720PFQ, 10799-10800PMFQT, 10831-10832PMMO
2. 11032-11037PMSA, 11042PMM
3. 11049PMQ, 11063PMS, 10866PMQT, 11038PMSA, 11064-11065PMS
4. FILTERS, LIGHTING, HEATERS, GATES, SUMP PUMP, WALL PACKS,
5. EXHAUST SYSTEM

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 12/8/20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SGT STORMS Date: 12/8/20

Signed: 

E-Mail:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

SITE AND BLDG #: NY039-01**WO# 10720****LOCATION/RM #:**

10799

10800

**MECHANIC
SIGNATURE**

DATE: 12/8/20

START TIME:

7am

FINISH TIME: 7:30am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	☒	☐	
2	Initial and Date Filter (if disposable)	☒	☐	
3	Initial and Date Yellow Maintenance Tag (if applicable)	☒	☐	
ASSET #	SIZE	QTY		NOTES/ ACTIONS
	Record Size :			
190917-248	20x16x1	1		
9891	20x20x2/20x30x2	4/12		
9896	8x23x1/11x33x16	14/6		
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly			
	All other filters get replaced annually But inspected Quarterly			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: