

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 12/9/20

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	3. _____
2. _____	4. _____

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO's 10729-10730PMFQT, 10808-10809PMMO, 10874-10875PMSA
2. 11043PMM, 11066PMS, 10731FQT, 10732FQT, 10836PMQT
3. 10876-10877PMSA, 11067PMS
4. FILTERS, GATES, HEATERS, WALL PACKS, FENCE, PTAC, EXHAUST
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 12/9/20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC PATRIC HANLON Date: 12/9/20

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, ELECTRIC

SITE AND BLDG #: NY051-02

MECHANIC
SIGNATURE: 

DATE: 12/9/20

LOCATION/RM #:

WO# 10877

ASSET # 10076

START TIME: 12:30pm

FINISH TIME: 1pm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check heater coils and associated piping for leaks or corrosion.	✓	/	no signs of leaks or corrosion
2	Clean heating coil. Brush vacuum where accessible.	✓	/	heating coil is clean
3	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections.	✓	/	electrical wiring wires and fuses are correct and in good shape
4	Inspect fan for bent blades, unbalance, excessive noise and vibration.	✓	/	no excessive noise or vibration
5	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	✓	/	no noise vibration or signs of overheating
6	Verify proper control by modulating the thermostat through complete cycle.	✓	/	
7	Inspect unit for proper operation and associated T-Stat	✓	/	thermostat functions properly
8	Inspect unit for overall condition and recommend for replacement or other needed repairs.	✓	/	units in good condition

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: