

Argent Inspections

Form AI-04

Pressure Vessel Inspection Report

Inspection Date 10/26/2019	Certificate Issued Yes	Expiration Date 10/26/2022	Prepared for Inspection Yes	Inspection Type: <input checked="" type="checkbox"/> Internal <input checked="" type="checkbox"/> External <input type="checkbox"/> Operational <input type="checkbox"/> Pressure	
Customer 99th R5Z1 MD066 USARC White Plains			UPV Location Name and/or Building Number OMS		
Address 4600 Fox Tail PL			UPV Location Address		
City White Plains		State MD	Zip 20695	City _____ State _____ Zip _____	
National Board # 705403	Property #	Manufacturer Morganton		Serial Number	
Pressure Vessel Type <input checked="" type="checkbox"/> Air Receiver <input type="checkbox"/> Autoclave <input type="checkbox"/> Heat Exchanger <input type="checkbox"/> Hot Water <input type="checkbox"/> Nitrogen <input type="checkbox"/> Oxygen <input type="checkbox"/> Other					Year Built 2018
Capacity 23 cubic feet	Design Pressure 225 psi	Operating Pressure	Test Pressure	Number of Safety Valves 1	
Valve 1	Valve Manufacturer CDI	Size 1/4"	Capacity (CFM) 199 scfm	Setting (PSI) 225 psi	Valve Condition Sat
Valve 2					
Reason(s) for Declining Certification					
Comments This compressed air receiver was inspected per UFC 3-430-07 and the National Board Inspection Code. It is a brand new installation. The vessel was measured ultrasonically for baseline information. It appears that the compressor that services this air receiver has never been lit off. The bottom of the air receiver has a drain fitting that is very difficult to access and/or manipulate. There is an automatic blow down device that is not connected to the air receiver but is connected to the compressor cooler.					
Inspector Commission 13314	Inspector Craig H. Bennett	Signature 			
Attachments No Pages	Jerry Kuykendall	Signature 			

Argent Inspections

Form AI-09

Pressure Vessel Inspection Certificate

Expiration Date 10/26/2022	Inspection Date 10/26/2019	National Board # 705403	Pressure Allowed 225 psi	Capacity 23 cubic feet
Customer 99th R5Z1 MD066 USARC White Plains		Manufacturer Morganton	Year Built 2018	
Location/Building # OMS		Serial #	Property #	
Inspection Type(s) Performed		Vessel Type		
<input checked="" type="checkbox"/> External <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Operational <input type="checkbox"/> Pressure		<input checked="" type="checkbox"/> Air Receiver <input type="checkbox"/> Autoclave <input type="checkbox"/> Heat Exchanger <input type="checkbox"/> Hot Water <input type="checkbox"/> Nitrogen <input type="checkbox"/> Oxygen <input type="checkbox"/> Other		
Commission # 13314	Inspector: Craig H. Bennett			
Signature 				

POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED Vessel