

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA050 Date of Visit: 11/12/19

Contractor Personnel on Site:

1. <u>BOND WATER TECHNOLOGIES</u>	3. _____
2. <u>BILL DAVIS</u>	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO 11210 ASSET 190918-248
2. _____
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jon Miller Date: 11/12/19

Signed: JP Miller

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: CPT Messalonia Friend Date: 11/12/19

Signed: JP Miller

Mail: _____

Tidewater, INC
 VA-050
 6002 Strathmore Rd.
 North Chesterfield VA 23232
 (410) 540-8700

Recorded By: Jon Miller
 (301) 580-9820
 jmiller@bondwater.com

2nd Floor Mechanical Room - HVAC Equipment

Test	Hot Loop	Chill Loop		
Conductivity (as mmhos)	156 3500 max	126 3500 max		
pH	8.7 8 - 10.5	9.0 8 - 10.5		
Molybdate (ppm as Mo)	0 50 min	0 50 min		

Opening Comment

Performed quarterly scheduled service visit.

Dropped off filters and filtration housings for chill water loop and hot loop. Marked appropriate taps for each filtration housing to be piped into.

Hot Water Loop

Online 

Corrosion inhibitor residual is low, attached chemical feed pump to hose bib on system and added 1 gallon of BOND 5011 treatment for additional corrosion protection.

Chill Water Loop

Online 

Corrosion inhibitor residual is low, attached chemical feed pump to hose bib on system and added 1 gallon of BOND 5011 treatment for additional corrosion protection.