

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE001 Date of Visit: 12/23/19

Contractor Personnel on Site:

1. <u>John Brown</u>	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO'S 11312FQ,11334MO,11370SA,11384PMF,11395PMQ,11400PMS,
2. 11313FQ,11371SA,11385PMF
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W Brown Date: 12/23/19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SSG Rod Spates Date: 12/23/19

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #: **DE001-01**MECHANIC
SIGNATURE:

12/23/19

LOCATION/RM #: **WO# 11312**
11384START TIME: **0900** FINISH TIME: **1630**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	/	/	
2	Initial and Date Filter (if disposable)	/	/	
3	Initial and Date Yellow Maintenance Tag (if applicable)	/	/	
ASSET #	SIZE	QTY	NOTES/ ACTIONS	
Record Size :				
1679	washable filters	1		
1680	washable filters	1		
1681	washable filters	1		
1682	washable filters	1		
1683	washable filters	1		
1684	washable filters	1		
1685	washable filters	1		
1686	washable filters	1		
1689	washable filters	1		
190918-104	washable filters	1		
190918-105	washable filters	1		
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly			
	All other filters get replaced annually But inspected Quarterly			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: