

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: _____ Date of Visit: **12/11/19**

Contractor Personnel on Site:

| | |
|----------|----------|
| 1. _____ | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. _____
2. _____
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W Brown Date: **12/11/19**

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC Phillip Cannon Date: **12/11/19**

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
VEHICLE EXHAUST REMOVAL

SITE AND BLDG #: **MD002-2**MECHANIC
SIGNATURE:DATE: **12/11/19**LOCATION/RM #: **WO# 11349 ASSET # 1505**START TIME: **0900** FINISH TIME: **1630**

| CHECK POINT | CHECKPOINT DESCRIPTION | TASK COMPLETE | | NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION) |
|---|---|---------------|----|---|
| | | YES | NO | |
| SPECIAL INSTRUCTIONS | | | | |
| 1 | Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. | | | |
| TO BE PERFORMED AT EACH INSPECTION SERVICE | | | | |
| 1 | Start and stop fan with local switch | | | |
| 2 | Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.-Inspect hoses -report issues -open CM ticket | | | |
| 3 | Inspect, adjust belts and pulleys. Replace belt as needed. | | | |
| 4 | Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness. | | | |
| 5 | Inspect fan for bent blades, unbalance, excessive noise and vibration. | | | |
| 6 | Clean fan as needed. | | | |
| 7 | Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks. | | | |
| 8 | Repair as needed | | | |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: