

**CERTIFICATION OF WORK  
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY067 Date of Visit: 1/12/21

Contractor Personnel on Site:

1. <u>PATRICK BROWN</u>	3. _____
2. _____	4. _____

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO #'S 11174 - ,11179,11180, -
2. 11185,11310,11362,11363,11364,11435,1144
3. 3,11365,11366
4. ASSET #'S 10570 - 10581 ,
5. 10612,10620,10621,10622,90917-450 ,  
190917-421

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Patrick Brown Date: 1/12/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SSG WILLIAM MONTES Date: 1/12/21


Signed: 

E-Mail: \_\_\_\_\_

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**MANUAL/AUTOMATIC OVERHEAD DOORS**

SITE AND BLDG #: **NY067 BLDG1**

LOCATION/RM #:	assembly hall	WO#	11362	ASSET #	10620
	kitchen		11363		10621

MECHANIC  
SIGNATURE: 

DATE: **1/12/21**START TIME: **10:15am**FINISH TIME: **11am**

CHECK POINT	CHECKPOINT DESCRIPTION	10622	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
			YES	NO	
<b>SPECIAL INSTRUCTIONS</b>					
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>			
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>					
1	Check with door operating personnel for any known deficiencies.	<input checked="" type="checkbox"/>			no known deficiencies
2	Inspect general arrangement of door and mechanism, mountings, standards, wind locks, anchor bolts, counterbalances, weather stripping, door sweeps etc. Clean, tighten, and adjust repair as required.	<input checked="" type="checkbox"/>			all are good
3	If applicable, operate with power from start to stop and at intermediate positions. Observe performance of various components, such as brake, limit switches, door operating speed, motor, gear box, etc. Clean and adjust as needed.	<input checked="" type="checkbox"/>			units function properly in all positions
4	Check operation of safety edges, stops, electric eye, treadle, or other operating devices. Clean and make required adjustments or repairs.	<input checked="" type="checkbox"/>			no adjustments needed
5	Check manual operation. Note brake release, motor disengagement, functioning or hand pulls, chains sprockets, clutch, etc.	<input checked="" type="checkbox"/>			units function properly manually
6	If applicable, examine all wiring, motor, starter, push button, etc., blow out or vacuum if needed.	<input checked="" type="checkbox"/>			all are clean
7	If applicable, inspect gear box, change or add oil as required.	<input checked="" type="checkbox"/>			
8	Perform required lubrication. Remove old or excess lubricant.	<input checked="" type="checkbox"/>			used PB Blaster garage door lubricant
9	Clean unit and mechanism thoroughly.	<input checked="" type="checkbox"/>			unit is clean
10	Clean up and remove all debris.	<input checked="" type="checkbox"/>			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**