

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 2/11/21

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>Patrick Brown</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S, 11486 , 11507 , 11513-11515 , 11542 ,
 2. 11559 , 11560 , 11588-11591 , 11785 , 11786 ,
 3. 11845 , 11858 , 11871 , 11872 , 11787
 4. ASSET#'S, 10043-10045 , 10051-10053 ,
 5. 10066-10069 , 10063 , 10079 , 190917-294 ,
279-284 , 299 , 295 , 296 , 286 , 301
-

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Patrick Brown Date: 2/11/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC PATRIC HANLON Date: 2/11/21

Signed: 


E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

VAV BOX

SITE AND BLDG #: **NY051 BLDG1**

LOCATION/RM #: **BLDG1** see below WO# ASSET # **10068**
10043

MECHANIC SIGNATURE:  DATE: **2-11-21**

START TIME: **7am** FINISH TIME: **9am**

CHECK POINT	CHECKPOINT DESCRIPTION	190917-279 TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒	☐	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If EMS system permits, check that the operating controls activate damper per design specifications.-	☒	☐	Record CFM AIR FLOW <u>289</u>
2	If required, check damper linkage for tightness and lightly lubricate.	☒	☐	
3	If required, inspect dampers for free movement.	☒	☐	
4	If required, inspect actuators for tightness to mounting brackets.	☒	☐	
5	As needed, tighten electrical connections to servo motor.	☒	☐	
6	Inspect unit for overall condition and recommend for replacement or other needed repairs.	☒	☐	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

WO#'S

11486
11507
11542
11785
11871