

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE007 Date of Visit: 2/6/20

Contractor Personnel on Site:

- | | |
|----------------------|----------|
| 1. <u>John Brown</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO'S 11587FQ, 11636MO, 11649QT, 11670SA, 11679PMA, 11689PMF,
2. 11588FQ, 11637MO, 11650QT
3. FILTERS, OUTSIDE LIGHTING, KITCHEN EQUIP, WATER HEATERS,
4. TIME CLOCK LIGHTINGVAV, ERV, MAKE UP AIR UNIT, GATE
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Johnny W Brown Date: 2/6/20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Danielle Barrett Date: 2/6/20

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

SITE AND BLDG #: DE007-02

LOCATION/RM #: **WO# 11588**

MECHANIC
SIGNATURE

MECHANIC SIGNATURE:  DATE: 2/6/20

START TIME: 0900 FINISH TIME: 1630

START TIME:**FINISH TIME:**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	/		
2	Initial and Date Filter (if disposable)	/		
3	Initial and Date Yellow Maintenance Tag (if applicable)	/		
ASSET #	SIZE	QTY		NOTES/ ACTIONS
	Record Size :			
1782	14x24x1	1		
1783	14x24x1	1		
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly			
	All other filters get replaced annually But inspected Quarterly			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: