

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE001 Date of Visit: 2/4/20

Contractor Personnel on Site:

1. <u>John Brown</u>	3. _____
2. _____	4. _____

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO'S 11634MO,11646QT, 11687PMF, 11699PMQ, 11647PMQT
2. OUTSIDE LIGHTING, REFRIGERATOR, WATER HEATERS TIME CLOCK LIGHTING,
3. AIR HANDLER FILTER,
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W Brown Date: 2/3/20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC Jose Mojica Date: 2/3/20

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
REACH-IN REFRIGERATORS/ FREEZERS

SITE AND BLDG #: DE001-01

MECHANIC
SIGNATURE:

DATE:

2/3/20

LOCATION/RM #: WO# 11646 ASSET # 1468

START TIME: 0900

FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	De-energize, lock out, and tag electrical circuits.	/	/	
2	If appliance is disposed, follow regulations concerning removal of refrigerants and disposal of the appliance.	/	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check with operating or area personnel for any deficiencies; verify cleaning program.	/	/	
2	Verify indicator light on; check compartment temperature.	/	/	
3	Examine evaporator for proper clearances/slope and air flow.	/	/	
4	Examine handles, hinges and tightness of door closure.	/	/	
5	Examine safety door release and fan shut down safety switch.	/	/	
6	Inspect lighting for burnt out lamps. Replace if required.	/	/	
7	Clean evaporator coil, evaporator drain pan, blowers, fans, motors, and drain piping as required; lubricate motor(s).	/	/	
8	Clean condenser coil and condensing unit section.	/	/	
9	Clean and inspect defrost evaporation trays/pans.	/	/	
10	Check operation of thermostats; calibrated as required.	/	/	
11	Check coil superheat and adjust to manufacturers recommendations.	/	/	
12	Inspect and service all electric motors.	/	/	
13	Check box floor for water or ice accumulation.	/	/	
14	Clean up area and note any deficiencies.	/	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
DOMESTIC HOT WATER HEATER - GAS

SITE AND BLDG #: **DE001 B-1**LOCATION/RM #: **WO# 11646 & ASSET # 1470 &**
DE001-B2 11647 1473MECHANIC
SIGNATURE: DATE: **2/6/20**START TIME: **0900** FINISH TIME: **1630**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/	/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/	/	
3	Use caution when working with natural gas fired equipment. Be aware of any smells (rotten egg) that could be a natural gas leak.	/	/	
4	Do not allow any open flames around equipment.	/	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Attach drain hose. Drain several gallons from tank to remove sediment.	/	/	
2	Manually check operation of safety valve. Check for corrosion around valve. Verify the safety valve inspection tag is in place. Ensure that no personnel are in area of relief piping discharge.	/	/	
3	Check all connections - electric, gas and water. Tighten as necessary.	/	/	
4	Check operation and setting of aquastat. Check hot water temperature with dial thermometer, and set aquastat at minimum value required for all uses.	/	/	
5	Drain storage and expansion tanks, and flush to remove sediment, scale, and solid at bottom of tank.	/	/	
6	Clean sight glasses on tanks.	/	/	
7	Clean strainer, check condition of traps. Report and repair leaks.	/	/	
8	Clean pump, controls, switches, and starters. Check operation of pump and condition of pump seal or packing, and replace as required.	/	/	
9	If applicable, Remove and inspect Anode, replace if necessary	/	/	
10	Clean up work area and remove trash.	/	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
TIME CLOCK, LIGHTING

SITE AND BLDG #: **DE001-01**MECHANIC
SIGNATURE:

DATE:

2/3/20

LOCATION/RM #:	WO# 11646	ASSET # 1472	START TIME: 0900
	11699	190918-109	FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean timeclock using a soft lint-free cloth and spray bottle of glass cleaner. Remove any dirt or grease build up.	/	/	
2	Check physical connections. Check wiring connections for tightness	/	/	
3	Verify the timeclock configuration, ensure proper operation.	/	/	
4	If applicable, check battery and replace as needed.	/	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: