

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA011 Date of Visit: 2/21/2020

Contractor Personnel on Site:

1. <u>RICHARD WALKER</u>	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO'S 11683PMA, 11691PMF, 11692PMF, 11707Q,
2. WATER FOUNTAIN, FILTERS, WATER HEATER, ICE MAKER, FREEZER
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard Walker Date: 2/21/2020

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Chris Chipp Date: 2/21/2020

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
DRINKING FOUNTAIN

SITE AND BLDG #: **VA011-01**MECHANIC
SIGNATURE: DATE: **2.14.2020**LOCATION/RM #: **Hallway/Gym** WO# **11683**ASSET # **191908-234**START TIME: **3pm**FINISH TIME: **5pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean compressor compartment including coils, fan, compressor and other components.	✓		
2	If applicable, replace filter as required.	✓		
3	Clean evaporator drain pan and drain piping as needed.	✓		
4	Check for water leaks in supply and drain lines.	✓		
5	Check electrical wiring for fraying and loose connections.	✓		
6	Lubricate fan bearing motors, as needed.	✓		
7	Check operation of unit for unusual noise, vibration, short <u>cycling</u> , and water temperature.	✓		
8	Check mouthpiece water pressure; adjust as required.	✓		
9	Clean unit, removing any dust, dirt, calcium buildup, etc.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: