

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**UNIT HEATER, HOT WATER**

SITE AND BLDG #: **MD002-01**

<b>LOCATION/RM #:</b>	<b>WO#</b> 11869	<b>ASSET #</b> 1817
	1815	1818

MECHANIC  
SIGNATURE:



DATE:

3/18/20

START TIME:

0900

FINISH TIME:

1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Schedule shutdown with operating personnel.	/	/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/	/	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check valve for signs of abnormal wear and leaks. Replace packing if needed.	/	/	
2	Clean the coils	/	/	
3	Comb the fins as needed.	/	/	
4	Clean all fans and motors.	/	/	
5	Check operation of controls and safeties.	/	/	
6	Lubricate as required.	/	/	
7	Check all motors, belts, pulleys, shafts, etc. for alignment.	/	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**