

**CERTIFICATION OF WORK  
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY127 Date of Visit: 3/12/21

Contractor Personnel on Site:

1. Patrick Brown 3. \_\_\_\_\_  
2. \_\_\_\_\_ 4. \_\_\_\_\_

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S, 11927, 12223, 12241, 11928, 12219, 12224, 12242,  
2. \_\_\_\_\_  
3. ASSET#'S, 190917-, 605-614, 617, 634, 635, 643, 628, 629,  
4. 655, 691-695, 697, 698, 705, 706, 724,  
5. \_\_\_\_\_

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Patrick Brown Date: 3/12/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: LARS LUFFMAN Date: 3/12/21

Signed: 

E-Mail: \_\_\_\_\_

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**VEHICLE EXHAUST REMOVAL**

SITE AND BLDG #: **NY127 BLDG2**LOCATION/RM #: **work bay** WO#**12224** ASSET # **190917-697**MECHANIC  
SIGNATURE:DATE: **3/12/21**START TIME: **3:30pm**FINISH TIME: **4pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Start and stop fan with local switch	✓		switch functions properly
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.-Inspect hoses -report issues -open CM ticket	✓		use Lucas heavy duty Grease
3	Inspect, adjust belts and pulleys. Replace belt as needed.	✓		adjusted belt
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.	✓		all are good
5	Inspect fan for bent blades, unbalance, excessive noise and vibration.	✓		no excessive noise or vibration
6	Clean fan as needed.	✓		fan is clean
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.	✓		no leaks found
8	Repair as needed	✓		no repairs needed

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: