

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY127 Date of Visit: 4/29/21

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>PATRICK BROWN</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S, 12486, 12487, 12506, 12495, 12507, 12510, 12508
2. ASSET#'S, 190917-, 677, 678, 685, 684, 724, 712, 728, 729
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 4/29/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: LARS LUFFMAN Date: 4/29/21


Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

INTERIOR LIGHTING

ACTIVITY AND BLDG #: NY127 BLDG3

MECHANIC
SIGNATURE: 

DATE: 4/29/21

LOCATION/RM #: BLDG3 WO# 12508 ASSET #190917-729

START TIME: 9am

FINISH TIME: 9:15 am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Visually check all accessible areas for burned out bulbs and/or flickering lights. Check with the facility manager to see if they know of any outages.	☒	☒	no flickering lights
2	Replace bulbs where applicable. Note quantity of bulbs replaced. If lift is required, schedule accordingly.	☒	☒	no bulbs needed to be replaced
3	Test light fixture. If light does not work, replace starters and/or ballasts as necessary.	☒	☒	no starters or ballast replaced
4	Note and report any needed electrical repairs.	☒	☒	no needed electrical repairs
5	Properly dispose of any non-working bulbs and ballasts.	☒	☒	
6	Clean up area and remove any trash.	☒	☒	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: