

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD002 Date of Visit: 9/21-23/20

Contractor Personnel on Site:

- | | |
|----------------------|----------|
| 1. <u>JOHN BROWN</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO'S 12645MO,12655QT,12696SA,12738-12739PMS,12657QT,12740-12742PMS
2. 12716PMF, 12727PMQ,12732PMS
3. LIGHTING, GREASE TRAPS, CIRCULATING PUMOPS, GLYCOL FEEDER,
4. GLYCOL EXP TANK, MINI SPLITS,EXP TANKS, DDC CONTROLER, EXT WALL PACKS
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W Brown Date: 9/23/20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Capt Brian Wharton Date: 9/23/20

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: MD002-05

MECHANIC
SIGNATURE:


DATE: 9/23/20

LOCATION/RM #: WO# 12741 ASSET # 190918-168

START TIME: 0900

FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect for structural defects, note needed repairs	/		
2	Push test buttons and observe light operation. Note any units that do not operate properly.- Report issues and open a CM ticket	/		
3	Clean exterior with dry cloth.	/		
4	For Exit lights check for proper arrow direction.	/		
5	Make and/or recommend any needed repairs.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be perfomed by: General Maintenance Worker

Additional Notes: