

CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY039 Date of Visit: 11-19-18

Contractor Personnel on Site:

1. Patrick Brown
2. _____
3. _____
4. _____

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 1031 QT, 1032 QT, 1278 QT, 1279 QT, 1280 QT, 1281 QT, 1282 QT, 1283 QT, 1284 QT, 1285 QT
2. Double Light, Single Gate, Chill Water Pump, Water Heater, Emergency Light, Emergency Exit Sign
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Patrick Brown Date: 11-19-18

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank:  Date: _____

Signed: 

E-Mail: dmq1qs.rushbctr@mail.mil

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: NY039 Bldg 3

LOCATION/RM #: Bldg 3 WO# 1284 ASSET # 9946

MECHANIC
SIGNATURE:

DATE: 11-13-18

START TIME: 100pm

FINISH TIME: 1:30pm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect for structural defects, note needed repairs	✓		Sent a report to Adam
2	Push test buttons and observe light operation. Note any units that do not operate properly.	✓		
3	Clean exterior with dry cloth.	✓		
4	For Exit lights check for proper arrow direction.	✓		Arrows were in proper direction
5	Make and/or recommend any needed repairs.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: