

CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA049 Date of Visit: 11.10.2020

Contractor Personnel on Site:

1. <u>RICHARD WALKER</u>	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO'S 12921FQ,1295PFQ,13006QT,13029SA,13039SA,13063PMF,13076PMQ
2. 13107PMS,13030SA,13031SA,13077PMQ,13007QT,13032SA,13066M,13078PMQ
3. FILTERS, KITCHEN EQUIP,HEATRES, AIRHANDLERS, CONDENSING UNITS,
4. CHILLER,LIGHTING,OUTDOOR AIR UNITS
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard Walker Date: 11.10.2020

Signed: Richard Walker

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Chris Chipp Date: 11.10.2020

Signed: Chris Chipp

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: **VA049-01**

LOCATION/RM #: **6xits** WO# **13076** ASSET # **3Y250**
3Y251

MECHANIC
SIGNATURE: *Richard Walker* DATE: **11.10.2020**

START TIME: **10am** FINISH TIME: **5PM**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect for structural defects, note needed repairs	✓	/	
2	Push test buttons and observe light operation. Note any units that do not operate properly.- Report issues and open a CM ticket	✓	/	
3	Clean exterior with dry cloth.	✓	/	
4	For Exit lights check for proper arrow direction.	✓	/	
5	Make and/or recommend any needed repairs.	✓	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: