

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE007 Date of Visit: 01/20/21

Contractor Personnel on Site:

1. John Brown 3. _____
2. _____ 4. _____

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. COW for December PM's
2. _____
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W Brown Date: 01/20/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Danielle Barrett Date: 01/20/21

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
VEHICLE EXHAUST REMOVAL

SITE AND BLDG #: DE007 B-2LOCATION/RM #: WO# 13224 ASSET # 1487-1494MECHANIC
SIGNATURE: DATE: 01/20/21START TIME: 0900FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Start and stop fan with local switch	/	/	
2	Check motor and fan shaft bearings for noise, vibraton, overheating; lubricate bearings.-Inspect hoses -report issues -open CM ticket	/	/	
3	Inspect, adjust belts and pulleys. Replace belt as needed.	/	/	
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.	/	/	
5	Inspect fan for bent blades, unbalance, excessive noise and vibration.	/	/	
6	Clean fan as needed.	/	/	
7	Visually inspect exaust system tubing and/or duct work for any damage that could result in leaks.	/	/	
8	Repair as needed	/	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be perfomed by: General Maintenance Worker

Additional Notes: