

CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA701-01-02 Date of Visit: 2/11/2021

Contractor Personnel on Site:

1. <u>Richard Walker</u>	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. _____
2. _____
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard Walker Date: 2/11/2021
Signed: Richard Walker

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Terry Casey Date: 2/11/2021
Signed: Terry Casey

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
DRINKING FOUNTAIN

SITE AND BLDG #: VA 701-01
LOCATION/RM #: RM 126 RM - Gym **WO#** 13405 **ASSET #** 133361 34346 35347

MECHANIC SIGNATURE: *Richard Walker* **DATE:** 2.9.21
START TIME: 1:30pm **FINISH TIME:** 3:15pm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean compressor compartment including coils, fan, compressor and other components.	✓		
2	If applicable, replace filter as required.	✓		
3	Clean evaporator drain pan and drain piping as needed.	✓		
4	Check for water leaks in supply and drain lines.	✓		
5	Check electrical wiring for fraying and loose connections.	✓		
6	Lubricate fan bearing motors, as needed.	✓		
7	Check operation of unit for unusual noise, vibration, short cycling, and water temperature.	✓		Water temp (54.6°, 55°)
8	Check mouthpiece water pressure; adjust as required.	✓		
9	Clean unit, removing any dust, dirt, calcium buildup, etc.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: