

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD019 Date of Visit: 01/29/21

Contractor Personnel on Site:

1. <u>John Brown</u>	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. <u>Jan PM MAINTENANCE</u>	_____
2. _____	_____
3. _____	_____
4. _____	_____
5. _____	_____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W Brown Date: 01/29/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC William Schaffer Date: 01/29/21

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GATES

SITE AND BLDG #: MD019 **MECHANIC SIGNATURE:**  **DATE:** 01/29/21
LOCATION/RM #: WO# 13344 & 13368 **ASSET #:** 1458, 2054 & 2055
START TIME: 0900 **FINISH TIME:** 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/	/	
2	Notify affected personnel before performing PM	/	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect all pivot points, hinges, latches, etc. Apply lubricant where needed, wiping off excess.	/	/	
2	Check all locking devices. Lubricate as required.	/	/	
3	Inspect gate support rollers and track, lubricate and clean as required.	/	/	
4	Check bolts, fasteners, and mounting hardware. Tighten as necessary.	/	/	
5	Check for any obstructions that prevent full swing or movement of the gate.	/	/	
6	Check that shrubs and trees are pruned clear of gate.	/	/	
7	Check hold open devices for proper operation. Lubricate as required.	/	/	
8	Check the top guard and ensure that it is properly fastened and the wires are tight. Tighten as required.	/	/	
9	If applicable, inspect hydraulic driveline (hoses, fittings, and gauges) for signs of leakage.	/	/	
10	If applicable, inspect limit switches for proper operation. Adjust as needed.	/	/	
11	If applicable, inspect photoeyes for proper operation and any signs of damage.	/	/	
12	If applicable, have site personnel operate gate with CAC Card insuring proper operation.	/	/	
13	If applicable, clean control cabinet, ensuring free from debris and insects.	/	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: