

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD019 Date of Visit: 03/22/21

Contractor Personnel on Site:

- | | |
|----------------------|----------|
| 1. <u>John Brown</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. PM MAINTENANCE
2. _____
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Johnny W Brown Date: 03/22/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC William Schaffer Date: 03/22/21

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

FILTER REPLACEMENT

SITE AND BLDG #: MD019 B-1

MECHANIC SIGNATURE:  DATE: 03/22/21

LOCATION/RM #: WO# 13662

START TIME: 0900 FINISH TIME: 1630

| CHECK POINT | CHECKPOINT DESCRIPTION | TASK COMPLETE | | NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION) |
|--|---|-------------------------------------|--------------------------|---|
| | | YES | NO | |
| TO BE PERFORMED AT EACH INSPECTION SERVICE | | | | |
| 1 | Check, clean, and/or replace filters as required. | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| 2 | Initial and Date Filter (if disposable) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| 3 | Initial and Date Yellow Maintenance Tag (if applicable) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| ASSET # | SIZE | QTY | | NOTES/ ACTIONS |
| | Record Size : | | | |
| 2049 | 24x24x2 & 12x24x2 | 2 & 2 | | |
| 2051 | washable filters | 4 | | |
| 2052 | 20x20x2, 16x20x2 | 6 & 3 | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | NOTE : Any AHU with outside air -Filter gets replaced Quarterly | | | |
| | All other filters get replaced annually But inspected Quarterly | | | |
| | | | | |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: