


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

LIGHTNING PROTECTION

MECHANIC

SIGNATURE: 

DATE: 4/5/21

SITE AND BLDG #: VA099-02

1443

LOCATION/RM #: exterior WO# 13693 ASSET # 1444

START TIME: 9am

FINISH TIME: 5pm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	During the first inspection, check that: a) All air terminals (lightning rods) are interconnected. b) At least two down conductors are installed with their own ground connection.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect air terminals for corrosion and rigid attachment to structure.	✓		
2	Examine conductors and all connections for corrosion, strong mechanical joints which provide good electrical conductivity, and loose or broken fasteners.	✓		
3	Check for loops, sharp bends (less than 8" radius) and frayed horizontal and vertical conductors.	✓		
4	Check for damaged guards and down conductors.	✓		
5	Inspect grounding attachment for permanency and corrosion (if practical).	✓		
6	Clean up work area and remove debris.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: