

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA048 Date of Visit: 4/14/21

Contractor Personnel on Site:

1. Richard Walker 3. _____
2. _____ 4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. Asset#'s
2. 1385, 1386, 1387, 1388, 1389, 1390, 1391, 1392, 1393, 1394
3. 1395, 1463, 2296, 3y259
4. _____
5. PM-AN, PM-MO, PM-SA, PMM.

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Richard Walker Date: 4/14/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Scott Grenier Date: 4/14/21

Signed: 

E-Mail: _____

13914	1385	PM-AN-1386	Columbus Electric			J-1502000-17 1-pc Thermostat, AnalogRM 117
13914	1386	PM-AN-1386	Trane			J-1502000-17 1-pc Thermostat, DigitalRM 111
13914	1387	PM-AN-1386	Honeywell			J-1502000-17 2-pc Thermostat, DigitalRM 122
13914	1388	PM-AN-1386	Honeywell			J-1502000-17 4-pc Thermostat, AnalogRM 122
13914	1389	PM-AN-1386	Fujitsu			J-1502000-17 1-pc Thermostat, DigitalRM 206
13914	1390	PM-AN-1386	Mitsubishi	EG7P		J-1502000-17 1-pc Thermostat, DigitalRM 207
13914	1391	PM-AN-1386	Robert Shaw			J-1502000-17 1-pc ThermostatRM 202
13914	1392	PM-AN-1386	Honeywell			J-1502000-17 1-pc Thermostat, AnalogRM 210
13914	1393	PM-AN-1386				J-1502000-17 1-pc Thermo SensorRM 212
13914	1394	PM-AN-1386	Robert Shaw			J-1502000-17 1-pc Thermostat, DigitalRM 204B
13914	1395	PM-AN-1386	Robert Shaw			J-1502000-17 1-pc Thermostat, DigitalRM 203
13925	1463	PM-MO-1463	Mid Atlantic Entry Syste			J-1502000-49 1-pc Automatic Gate SglGate,Auto,Cantilever WestParkEnt-Egress (35ft Gate)
13929	2296	PM-SA-2296DH	Edison			J-1502000-14 1-pc Dehumidifier-Can't locate might be in Vault need access
13934	3Y259	PMM-3Y259			FB0U170502587	9-pc MEP Pole Lights MEP LOT

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
DEHUMIDIFIER

SITE AND BLDG #: VA048-01
LOCATION/RM #: vault **WO#** 13929 **ASSET #** 2296

MECHANIC
SIGNATURE: *Rick Walker* **DATE:** 4/14/21
START TIME: 9am **FINISH TIME:** 5pm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check water inlet and outlet for any leaks, repair as needed.	✓		
2	Clean and/or replace filter as needed. -Record space humidity	✓		Space Humidity <u>35</u> %
3	If applicable, check hours per usage, replace tanks's as needed.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

Washable filter