

**CERTIFICATION OF WORK  
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD003 Date of Visit: 05/21/21

Contractor Personnel on Site:

1. John Brown      3. \_\_\_\_\_  
2. \_\_\_\_\_      4. \_\_\_\_\_

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. \_\_\_\_\_  
2. \_\_\_\_\_  
3. \_\_\_\_\_  
4. \_\_\_\_\_  
5. \_\_\_\_\_


76

65

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Johnny W Brown Date: 05/21/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SGT Nicholas Cruz Date: 05/21/21

Signed: 

E-Mail: \_\_\_\_\_

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**ICE MAKER**

MD003 B-1

SITE AND BLDG #:

MECHANIC  
SIGNATURE:

DATE: 05/21/21

LOCATION/RM #:

WO# 14039

ASSET # 1511

START TIME:

0900

FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	De-energize, lock out, and tag electrical circuits.	/	/	
2	Only approved cleaning chemicals shall be used.	/	/	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check with operating or area personnel for any deficiencies; verify cleaning program.	/	/	
2	Visually check for refrigerant, oil and water leaks.	/	/	
3	Inspect ice condition/size.	/	/	
4	Clean air filter	/	/	
5	As needed, drain and clean unit with proper ice machine cleaning solution. Drain and clean at a minimum of annually.	/	/	
6	Check date on water filter, Replace as needed. Water filters should be changed annually at a minimum.	/	/	
7	Check and tighten any loose screw-type electrical connections.	/	/	
8	Check all controls; adjust if necessary.	/	/	
9	Examine water connection; open and close water valve; test ice dispensing valve and (door) metering adjustment.	/	/	
10	Check and clear ice machine draining system (drain vent, strainer, trap).	/	/	
11	Examine condition of bin doors-closure, hinges, gaskets, handles and ease of slide; lubricate as required. Check storage bin condition.	/	/	
12	Clean motor, compressor, and condenser coil.	/	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**REACH-IN REFRIGERATORS/ FREEZERS**

SITE AND BLDG #: **MD003 B-1**LOCATION/RM #: **WO# 14039** ASSET # **1512**MECHANIC  
SIGNATURE: DATE: **05/21/21**START TIME: **0900**FINISH TIME: **1630**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	De-energize, lock out, and tag electrical circuits.	/	/	
2	If appliance is disposed, follow regulations concerning removal of refrigerants and disposal of the appliance.	/	/	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check with operating or area personnel for any deficiencies; verify cleaning program.	/	/	
2	Verify indicator light on; check compartment temperature.	/	/	
3	Examine evaporator for proper clearances/slope and air flow.	/	/	
4	Examine handles, hinges and tightness of door closure.	/	/	
5	Examine safety door release and fan shut down safety switch.	/	/	
6	Inspect lighting for burnt out lamps. Replace if required.	/	/	
7	Clean evaporator coil, evaporator drain pan, blowers, fans, motors, and drain piping as required; lubricate motor(s).	/	/	
8	Clean condenser coil and condensing unit section.	/	/	
9	Clean and inspect defrost evaporation trays/pans.	/	/	
10	Check operation of thermostats; calibrated as required.	/	/	
11	Check coil superheat and adjust to manufacturers recommendations.	/	/	
12	Inspect and service all electric motors.	/	/	
13	Check box floor for water or ice accumulation.	/	/	
14	Clean up area and note any deficiencies.	/	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**SUMP PUMP**

SITE AND BLDG #: MD003 B-1MECHANIC  
SIGNATURE: DATE: 05/21/21LOCATION/RM #: WO# 14039 ASSET # 1514START TIME: 0900 FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/	/	
2	Excessive sediment and debris, not removed by flushing the pit should be handled on a project basis, and not considered under this standard.	/	/	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Remove cover plates and flush pit.	/	/	
2	Inspect check valve.	/	/	
3	Inspect interior of pit for cracks.	/	/	
4	Inspect cover plate is in place	/	/	
5	Insuure the unit is operating properly, report any deficiencies	/	/	
6	Clean up work area and remove all debris.	/	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**DOMESTIC HOT WATER HEATER - GAS**

**SITE AND BLDG #:** MD003 B-1  
**LOCATION/RM #:** WO# 14039 ASSET # 1513

**MECHANIC  
SIGNATURE:**

**DATE:** 05/21/21

**START TIME:** 0900

**FINISH TIME:** 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/	/	
2	Use caution when working with natural gas fired equipment. Be aware of any smells (rotten egg) that could be a natural gas leak.	/	/	
3	Do not allow any open flames around equipment.	/	/	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Attach drain hose. Drain several gallons from tank to remove sediment.	/	/	
2	Manually check operation of safety valve. Check for corrosion around valve. Verify the safety valve inspection tag is in place. Ensure that no personnel are in area of relief piping discharge.	/	/	
3	Check all connections - electric, gas and water. Tighten as necessary.	/	/	
4	Check operation and setting of aquastat. Check hot water temperature with dial thermometer, and set aquastat at minimum value required for all uses.	/	/	
5	Clean water heater exterior.	/	/	
6	Clean pump, controls, switches, and starters. Check operation of pump and condition of pump seal or packing, and replace as required.	/	/	
7	Soap test for gas leaks, if leaks are found notify facility manager and AFOS immediately.	/	/	
8	Clean up work area and remove trash.	/	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**