

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY013 Date of Visit: 8/24/21

Contractor Personnel on Site:

1. <u>PATRICK BROWN</u>	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 14179-14188 , 14341 , 14349 , 14366 ,
2. ASSET#'S , 9220 , 9222 , 9240 , 9241 ,
3. 9243-9245 , 9261-9263 , 190917-, 131 , 102 ,
4. 103 , 132 , 119 , 124-126
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 8/24/13

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC KEVIN STEWART Date: 8/24/21


Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: **NY013 BLDG2**

LOCATION/RM #: **BLDG2** WO# **14187,** ASSET # **9262,**
14188 **9263**

MECHANIC
SIGNATURE: DATE: **8/24/21**START TIME: **12:30pm**FINISH TIME: **12:45pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect for structural defects, note needed repairs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	no structural defects
2	Push test buttons and observe light operation. Note any units that do not operate properly.- Report issues and open a CM ticket	<input checked="" type="checkbox"/>	<input type="checkbox"/>	units function properly
3	Clean exterior with dry cloth.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	units have been wiped down
4	For Exit lights check for proper arrow direction.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Arrow directions are proper
5	Make and/or recommend any needed repairs.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	no repairs needed

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: