

CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY039 Date of Visit: 12-4-18 / 12-6-18 / 12-17-18

Contractor Personnel on Site:

1. Patrick Brown
2. _____
3. _____
4. _____

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 1383 FQT, 1384 FQT, 1419 MO, 1420 MO, 1647 SA, 1648 SA, 1649 SA, 1650 SA
2. 1651 SA, 1652 SA, 1460 QT, 1653 SA, 1654 SA
3. Air Handler, Fan Coil, DOuble Light, Single Gate, Unit Heater, Floor Mounted
4. Fan Coil, Unit Heater, Double Light, Exhaust System, Unit Heater
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 12-21-18

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Douglas Rusho Date: 12/21/18

Signed: 

E-Mail: douglas.rusho.ctr@mail.mil

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #: BF NY039-Bldg 1
PO.V. 1419 9932
LOCATION/RM #: Parking WO# 1652 ASSET # 9931

MECHANIC
SIGNATURE: PR

DATE: 12-17-18

START TIME: 7: AM

FINISH TIME: 8: AM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Schedule and coordinate work with operating personnel.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Open and tag switch.	✓		
2	Inspect visual condition of wiring. Look for evidence of overheating.	✓		No overheating Wiring looks good
3	Check for proper light operation.	✓		Lights are not operating correctly
4	Test operation of automatic switches/ time clock/ photocells if applicable.	✓		Unsure to lights will not turn on
5	Inspect light pole and mounting devices for deficiencies.	✓		Light pole is good
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: Light Bulbs are good and there is power to the units But they are not working
 Doug Rusko and I are suggesting they be replaced