

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Rockville MD021 Date of Visit: July 7, 2021

Contractor Personnel on Site:

1. Nicholas LoRusso
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

**Service Call Number**

CSS# 30975 WO# 14380 Estimate #1807

HP Invoice #1954

**Description of Repairs**

- Replaced (3) Galaxy 1035 DRM Boards in Main Building Panel. Full Access Control System Test performed including Motor Pool Building, Drill Hall Door Reader was discovered has bad "0" in keypad. - It is recommended that it be replaced.

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Nicholas LoRusso Date: 7/7/2021

Signed: Nicholas LoRusso

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: No personnel available Date: \_\_\_\_\_

Signed: at the time of site visit

E-Mail: \_\_\_\_\_